


Appendix D: Facility Reports for Downtown Parking Lots

Parking Lot	Cost Estimate
Parking Lot 1	\$14,500
Parking Lot 2	\$17,500
Parking Lot 3	\$13,000
Parking Lot 4	\$5,500
Parking Lot 5	\$24,500
Parking Lot 6	\$25,000
Parking Lot 7 (Not Surveyed)	\$0
Parking Lot 8	\$31,500
Parking Lot 9	\$20,500
Parking Lot 10	\$2,500
TOTAL	\$154,500



Downtown Parking Lot 1 - PROW
Main Street at State Street
Los Altos, CA

Parking Lot 1 PROW

1 - 1		Parking Area	Priority: 1
Install sign			\$500
Notes: Signs are posted at 79" AFF, not in POT. No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded. Stall is 8' wide by 17'-3" long (9'x18' required).			
State: 1129B.3, 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: Access aisle is 16'-8" long (18' required). Hatchlines are worn and faded. The words "No Parking" are not painted at the access aisle.			
State: 1129B.3, 1129B.3.1			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of access aisle are 2.3%-3% (2% max.)			
State: 1129B.3.4			
Federal: -			
Install sign for unauthorized parking			\$500
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			

Parking Lot 1 PROW

1 - 2		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: Hatchlines are worn and faded. The words "No Parking" are not painted at the access aisle.			
State: 1129B.3, 1129B.3.1			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes are 2.1%-3.2% (2% max.)			
State: 1129B.3.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			

Parking Lot 1 PROW

1 - 3 Parking Area		Priority: 1
Install sign		\$500
Notes: No "Minimum Fine \$250" sign posted. Sign is turned perpendicular to space.		
State: 1129B.4		
Federal: -		
Provide or modify accessible spaces		\$500
Notes: Accessible spaces are not painted blue. ISA faded.		
State: 1129B.4		
Federal: -		
Provide or modify accessible access aisles		\$1,000
Notes: Hatchlines are warn and faded. The words "No Parking" are not painted at the access aisle. Access aisle is 8'-6" long (18' required).		
State: 1129B.3, 1129B.3.1		
Federal: -		
Install sign for unauthorized parking		\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.		
State: 1129B.4		
Federal: -		

Parking Lot 1 PROW

1 - 4		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted. Sign is turned perpendicular to space.			
State: 1129B.4			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: Hatchlines are warn and faded. The words "No Parking" are not painted at the access aisle.			
State: 1129B.3, 1129B.3.1			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of parking space are 2.1%-4.0% (2% max.) Slopes of access aisle are 2.1%-4.3% (2% max.)			
State: 1129B.3.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			

Parking Lot 1 PROW

1 - 5		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted. Sign posted at 76" AFF (80" min.).			
State: 1129B.4			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded. Parking stall is 17' long (18' min.).			
State: 1129B.3, 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: Hatchlines are warn and faded. The words "No Parking" are not painted at the access aisle.			
State: 1129B.3, 1129B.3.1			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of parking space are 2.1%-4.3% (2% max.) Slopes of access aisle at asphalt are 2.1%-4.5% (2% max.)			
State: 1129B.3.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			



Downtown Parking Lot 2 - PROW
Main Street at State Street
Los Altos, CA

Parking Lot 2 PROW

1 - 1 Parking Area		Priority: 1
Install sign		\$500
Notes: Signs are posted at 73" AFF (80" min). No "Minimum Fine \$250" sign posted.		
State: 1129B.4		
Federal: -		
Install sign for unauthorized parking		\$500
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.		
State: 1129B.4		
Federal: -		
Provide or modify accessible access aisles		\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle is 15' long (18' required).		
State: 1129B.3, 1129B.3.1		
Federal: -		
Provide or modify accessible spaces		\$500
Notes: Accessible spaces are not painted blue. ISA faded and not visible when vehicle is present.		
State: 1129B.4		
Federal: -		

Parking Lot 2 PROW

1 - 2		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle is 15' long (18' required).			
State: 1129B.3, 1129B.3.1			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded and not visible when vehicle is present.			
State: 1129B.4			
Federal: -			

Parking Lot 2 PROW

1 - 3		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded and not visible when vehicle is present.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle.			
State: 1129B.3.1			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of access aisle are 2.3%-4.5% (2% max.)			
State: 1129B.3.4			
Federal: -			

Parking Lot 2 PROW

1 - 4		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle.			
State: 1129B.3.1			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded and not visible when vehicle is present. Stall is 17' long (18' required).			
State: 1129B.3, 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of access aisle are 2.1%-3.7% (2% max.)			
State: 1129B.3.4			
Federal: -			

Parking Lot 2 PROW

1 - 5		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle.			
State: 1129B.3.1			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded and not visible when vehicle is present.			
State: 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of access aisle are 2.1%-2.9% (2% max.) Slopes of stall are 2.1%-6.9% (2% max.)			
State: 1129B.3.4			
Federal: -			

Parking Lot 2 PROW

1 - 6	Parking Area	Priority: 1
Install sign		\$500
Notes: No "Minimum Fine \$250" sign posted.		
State: 1129B.4		
Federal: -		
Install sign for unauthorized parking		\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.		
State: 1129B.4		
Federal: -		
Provide or modify accessible access aisles		\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle is 11' long (18' required).		
State: 1129B.3, 1129B.3.1		
Federal: -		
Provide or modify accessible spaces		\$500
Notes: Accessible spaces are not painted blue. ISA faded and not visible when vehicle is present.		
State: 1129B.4		
Federal: -		

Parking Lot 2 PROW

1 - 7		Parking Area	Priority: 1
Install sign			\$500
Notes: Signs are posted at 79" AFF (80" min.)			
State: 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle is 17'-9" long (18' required).			
State: 1129B.3, 1129B.3.1			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded. Stall is 8' wide (9 required).			
State: 1129B.3, 1129B.4			
Federal: -			



1-3
1-2
1-1

1-5
1-4

1-6

Downtown Parking Lot 3 - PROW
Main Street at State Street
Los Altos, CA

Parking Lot 3 PROW

1 - 1 Parking Area		Priority: 1
Install sign		\$500
Notes:	No "Minimum Fine \$250" sign posted.	
State:	1129B.4	
Federal:	-	
Install sign for unauthorized parking		\$500
Notes:	No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.	
State:	1129B.4	
Federal:	-	
Provide or modify accessible access aisles		\$1,000
Notes:	The words "No Parking" are not painted at the access aisle.	
State:	1129B.3.1	
Federal:	-	
Provide or modify accessible spaces		\$500
Notes:	Accessible spaces are not painted blue. ISA faded and not visible when vehicle is present. Stall is 8' wide (9' required).	
State:	1129B.3, 1129B.4	
Federal:	-	

Parking Lot 3 PROW

1 - 2		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle.			
State: 1129B.3.1			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded and not visible when vehicle is present.			
State: 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of stall are 2.1%-4.2% (2% max.)			
State: 1129B.3.4			
Federal: -			

Parking Lot 3 PROW

1 - 3		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle.			
State: 1129B.3.1			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded and not visible when vehicle is present. Stall is 8' wide (9' required).			
State: 1129B.3, 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of stall are 2.1%-2.6% (2% max.) Slopes of access aisle are 2.1%-2.8% (2% max.)			
State: 1129B.3.4			
Federal: -			

Parking Lot 3 PROW

1 - 4		Parking Area	Priority: 1
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Van Stall is 8'-6" wide (9' required).			
State: 1129B.3			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of stall are 2.1%-3.7% (2% max.) Slopes of access aisle are 2.1%-2.6% (2% max.)			
State: 1129B.3.4			
Federal: -			
1 - 5		Parking Area	Priority: 1
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of stall are 2.1%-3.7% at tree root (2% max.) Slopes of access aisle are 2.1%- 3.9% (2% max.)			
State: 1129B.3.4			
Federal: -			
1 - 6		Parking Area	Priority: 1
Reposition controls and outlets			\$2,000
Notes: Reach range at electrical charging station is 55" AFF (48" max.)			
State: -			
Federal: 308.3			



1-1

Downtown Parking Lot 4 - PROW
Main Street at State Street
Los Altos, CA

Parking Lot 4 PROW

1 - 1		Parking Area	Priority: 1
Provide or modify accessible spaces			\$3,000
Notes: Of 59 spaces provided, 1 is accessible (3 required). Accessible space is not painted blue. ISA faded. Stall width is 8'-6" (9' min.).			
State: 1129B.1, 1129B.3, 1129B.4			
Federal: -			
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle ranges from 3" to 8' wide (60" min).			
State: 1129B.3, 1129B.3.1			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of stall are 7%-15% at drain (2% max.) Slopes of access aisle are 3.2%-5.4% (2% max.)			
State: 1129B.3.4			
Federal: -			



Downtown Parking Lot 5 - PROW
Main Street at State Street
Los Altos, CA

Parking Lot 5 PROW

1 - 1		Parking Area	Priority: 1
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded. Stall is 8' wide (9' required).			
State: 1129B.3, 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$500
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle.			
State: 1129B.3.1			
Federal: -			
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
1 - 2		Parking Area	Priority: 1
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded. Stall is 8' wide (9' required).			
State: 1129B.3, 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle.			
State: 1129B.3.1			
Federal: -			
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			

Parking Lot 5 PROW

1 - 3		Parking Area	Priority: 1
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded. Stall is 8'-6" wide (9' required).			
State: 1129B.3, 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle is 14' long (18' min.).			
State: 1129B.3.1			
Federal: -			
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted. Sign obscured by tree.			
State: 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of access aisle are 2.1%-3.1% (2% max.) Slopes of stall are 2.1%-2.9% (2% max.)			
State: 1129B.3.4			
Federal: -			

Parking Lot 5 PROW

1 - 4		Parking Area	Priority: 1
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded. Stall is 15' long (18' required).			
State: 1129B.3, 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle is 15' long (18' min.).			
State: 1129B.3, 1129B.3.1			
Federal: -			
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of access aisle are 2.1%-2.8% at cracks (2% max.)			
State: 1129B.3.4			
Federal: -			

Parking Lot 5 PROW

1 - 5	Parking Area	Priority: 1
Provide or modify accessible spaces		\$500
Notes: Accessible spaces are not painted blue. ISA faded. Stall is 12'-4" long (18' required).		
State: 1129B.3, 1129B.4		
Federal: -		
Install sign for unauthorized parking		\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.		
State: 1129B.4		
Federal: -		
Provide or modify accessible access aisles		\$1,000
Notes: The words "No Parking" are not painted at the access aisle. No access aisle provided.		
State: 1129B.3, 1129B.3.1		
Federal: -		
Install sign		\$500
Notes: No "Minimum Fine \$250" sign posted. Vertical sign is mounted at 46.5" AFF (80" required).		
State: 1129B.4		
Federal: -		
Regrade surface		\$1,000
Notes: Slopes of access aisle are 2.1%-2.8% at cracks (2% max.)		
State: 1129B.3.4		
Federal: -		

Parking Lot 5 PROW

1 - 6		Parking Area	Priority: 1
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded.			
State: 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle.			
State: 1129B.3.1			
Federal: -			
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted. No designation sign provided.			
State: 1129B.4			
Federal: -			
1 - 7		Parking Area	Priority: 1
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded.			
State: 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle.			
State: 1129B.3.1			
Federal: -			
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			

Parking Lot 5 PROW

3 - 1 Curb Ramp		Priority: 1
Provide detectable warning strip		\$1,000
Notes: Truncated dome plate is 24" wide (36" min.).		
State: 1127B.5.7, IR11B-4		
Federal: -		
Provide level landing		\$5,000
Notes: Level landing at top is sloped at 2.8% (2% max.).		
State: 1127B.5.4		
Federal: -		
Provide surface texturing		\$1,000
Notes: No grooved border provided.		
State: 1127B.5.6		
Federal: -		



Downtown Parking Lot 6 - PROW
Main Street at State Street
Los Altos, CA

Parking Lot 6 PROW

1 - 1		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle is not outlined in blue.			
State: 1129B.3, 1129B.3.1			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA is not visible when vehicle is present.			
State: 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of access aisle are 2.1%-2.4% (2% max.)			
State: 1129B.3.4			
Federal: -			
1 - 2		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle is 9' long (18' required). Access aisle is not outlined in blue.			
State: 1129B.3, 1129B.3.1			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA is not visible when vehicle is present.			
State: 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of access aisle are 2.1%-3.8% (2% max.) Slopes of stall are 2.1%-3.1% (2% max.)			
State: 1129B.3.4			
Federal: -			

Parking Lot 6 PROW

1 - 3		Parking Area	Priority: 1
Install sign			\$500
Notes:	No "Minimum Fine \$250" sign posted.		
State:	1129B.4		
Federal:	-		
Provide or modify accessible access aisles			\$1,000
Notes:	The words "No Parking" are not painted at the access aisle. Access aisle is not outlined in blue.		
State:	1129B.3, 1129B.3.1		
Federal:	-		
Provide or modify accessible spaces			\$500
Notes:	Accessible spaces are not painted blue. ISA faded and is not visible when vehicle is present.		
State:	1129B.4		
Federal:	-		
Regrade surface			\$1,000
Notes:	Slopes of access aisle are 2.1%-3.7% (2% max.) Slopes of stall are 2.1%-2.3% (2% max.)		
State:	1129B.3.4		
Federal:	-		

Parking Lot 6 PROW

1 - 4		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle is 14' long (18' required). Access aisle is not outlined in blue.			
State: 1129B.3, 1129B.3.1			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA is not visible when vehicle is present. Stall is 7'-5" wide by 16' long (9'x18' required).			
State: 1129B.3, 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of access aisle to drain is 17.2% (2% max.) Slopes of stall to drain is 5.1% (2% max.)			
State: 1129B.3.4			
Federal: -			

Parking Lot 6 PROW

1 - 5		Parking Area	Priority: 1
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle is 12'-4" long (18' required). Access aisle is not outlined in blue.			
State: 1129B.3, 1129B.3.1			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded.			
State: 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Running slope of access aisle is 3.4% (2% max.)			
State: 1129B.3.4			
Federal: -			
Provide an accessible path of travel			\$10,000
Notes: Built-up asphalt in designated access route has cross slope of 10.1%.			
State: 1114B.1.2			
Federal: 206.2			



Downtown Parking Lot 7 - PROW
Main Street at State Street
Los Altos, CA

Parking Lot 7 PROW

1 - 1		Parking Area	Priority: 1
Provide or modify accessible spaces			\$0
Notes:	Parking Lot 7 accessible spaces are within construction staging area and were not surveyed.		
State:	-		
Federal:	-		



Downtown Parking Lot 8 - PROW
Main Street at State Street
Los Altos, CA

Parking Lot 8 PROW

1 - 1		Parking Area	Priority: 1
Install sign for unauthorized parking			\$500
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Provide an accessible path of travel			\$10,000
Notes: Accessible route is 37.75" (48" min.).			
State: 1114B.1.2			
Federal: 206.2			
Provide or modify accessible access aisles			\$1,000
Notes: The words "No Parking" are not painted at the access aisle. Access aisle is 11'-6" long (18' required).			
State: 1129B.3, 1129B.3.1			
Federal: -			
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded and is not visible when vehicle is present. Stall is 8' wide (9' required).			
State: 1129B.3, 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of access aisle are 2.1%-3.9% (2% max.) Slopes of stall are 2.1%-2.7% (2% max.)			
State: 1129B.3.4			
Federal: -			

Parking Lot 8 PROW

1 - 2		Parking Area	Priority: 1
Install sign for unauthorized parking			\$0
Notes:	No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.		
State:	1129B.4		
Federal:	-		
Install sign			\$500
Notes:	No "Minimum Fine \$250" sign posted.		
State:	1129B.4		
Federal:	-		
Provide or modify accessible access aisles			\$1,000
Notes:	The words "No Parking" are not painted at the access aisle. Access aisle is 16'-8" long (18' required). Access aisle is not outlined in blue.		
State:	1129B.3, 1129B.3.1		
Federal:	-		
Provide or modify accessible spaces			\$500
Notes:	Accessible spaces are not painted blue. ISA faded and is not visible when vehicle is present. Stall is 8' wide by 16'-8" long (9'x18' required).		
State:	1129B.3, 1129B.4		
Federal:	-		
Regrade surface			\$1,000
Notes:	Slopes of access aisle are 2.1%-2.3% (2% max.) Slopes of stall are 2.1%-2.2% (2% max.)		
State:	1129B.3.4		
Federal:	-		

Parking Lot 8 PROW

1 - 3		Parking Area	Priority: 1
Install sign for unauthorized parking			\$0
Notes:	No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.		
State:	1129B.4		
Federal:	-		
Install sign			\$500
Notes:	No "Minimum Fine \$250" sign posted.		
State:	1129B.4		
Federal:	-		
Provide or modify accessible access aisles			\$1,000
Notes:	The words "No Parking" are not painted at the access aisle. Access aisle is not outlined in blue.		
State:	1129B.3, 1129B.3.1		
Federal:	-		
Provide or modify accessible spaces			\$500
Notes:	Accessible spaces are not painted blue. ISA faded and is not visible when vehicle is present. Stall is 8' wide by 17' long (9'x18' required).		
State:	1129B.3, 1129B.4		
Federal:	-		
Regrade surface			\$1,000
Notes:	Slopes of stall are 2.1%-4.5% (2% max.)		
State:	1129B.3.4		
Federal:	-		

Parking Lot 8 PROW

1 - 4		Parking Area	Priority: 1
Install sign for unauthorized parking			\$0
Notes:	No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.		
State:	1129B.4		
Federal:	-		
Install sign			\$500
Notes:	No "Minimum Fine \$250" sign posted.		
State:	1129B.4		
Federal:	-		
Provide or modify accessible access aisles			\$1,000
Notes:	The words "No Parking" are not painted at the access aisle. Access aisle is 11'-6" long (18' required). Access aisle is not outlined in blue.		
State:	1129B.3, 1129B.3.1		
Federal:	-		
Provide or modify accessible spaces			\$500
Notes:	Accessible spaces are not painted blue. ISA faded and is not visible when vehicle is present. Stall is 8' wide (9' required).		
State:	1129B.3, 1129B.4		
Federal:	-		
Regrade surface			\$1,000
Notes:	Slope of access aisle is 2.1% (2% max.). Tree root.		
State:	1129B.3.4		
Federal:	-		

Parking Lot 8 PROW

1 - 5		Parking Area	Priority: 1
Install sign for unauthorized parking			\$0
Notes:	No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.		
State:	1129B.4		
Federal:	-		
Install sign			\$500
Notes:	No "Minimum Fine \$250" sign posted.		
State:	1129B.4		
Federal:	-		
Provide or modify accessible access aisles			\$1,000
Notes:	The words "No Parking" are not painted at the access aisle. Access aisle is not outlined in blue.		
State:	1129B.3, 1129B.3.1		
Federal:	-		
Provide or modify accessible spaces			\$500
Notes:	Accessible spaces are not painted blue. ISA faded and is not visible when vehicle is present. Stall is 7'-10" wide (9' required).		
State:	1129B.3, 1129B.4		
Federal:	-		
Regrade surface			\$1,000
Notes:	Slopes of access aisle are 2.1%-3.6% (2% max.) Slopes of stall are 2.1%-4.7% (2% max.). Tree root.		
State:	1129B.3.4		
Federal:	-		

Parking Lot 8 PROW

1 - 6		Parking Area	Priority: 1
Install sign for unauthorized parking			\$0
Notes:	No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.		
State:	1129B.4		
Federal:	-		
Install sign			\$500
Notes:	No "Minimum Fine \$250" sign posted.		
State:	1129B.4		
Federal:	-		
Provide or modify accessible access aisles			\$1,000
Notes:	The words "No Parking" are not painted at the access aisle. Access aisle is not outlined in blue.		
State:	1129B.3, 1129B.3.1		
Federal:	-		
Provide or modify accessible spaces			\$500
Notes:	Accessible spaces are not painted blue. ISA faded and is not visible when vehicle is present.		
State:	1129B.3, 1129B.4		
Federal:	-		
Regrade surface			\$1,000
Notes:	Slopes of access aisle are 2.1%-2.2% (2% max.) Slopes of stall are 2.1%-3.2% (2% max.)		
State:	1129B.3.4		
Federal:	-		

Parking Lot 8 PROW

1 - 7 Parking Area		Priority: 1
Install sign		\$500
Notes: No vertical signage provided.		
State: 1129B.4		
Federal: -		
Provide or modify accessible access aisles		\$1,000
Notes: No access aisle provided.		
State: 1129B.3		
Federal: -		
Regrade surface		\$1,000
Notes: 2.6% CS in access aisle at tree root.		
State: 1129B.3.4		
Federal: -		
Provide or modify accessible spaces		\$500
Notes: No ISA provided.		
State: 1129B.4		
Federal: -		



- 1-2
- 3-1
- 1-4
- 1-1
- 1-3

Downtown Parking Lot 9 - PROW
Main Street at State Street
Los Altos, CA

Parking Lot 9 PROW

1 - 1		Parking Area	Priority: 1
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded. Stall is 16'-8" long (18' required). 4 accessible spaces are provided (5 required for 138 spaces).			
State: 1129B.1, 1129B.3, 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: Access aisle is not outlined in blue. The words "No Parking" are not painted at the access aisle. Access aisle is 16'-8" long (18' required). Tree root crack.			
State: 1129B.3, 1129B.3.1			
Federal: -			
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Install sign for unauthorized parking			\$500
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of stalls are 2.1%-3.3% (2% max.)			
State: 1129B.3.4			
Federal: -			

Parking Lot 9 PROW

1 - 2	Parking Area	Priority: 1
Provide or modify accessible spaces		\$3,500
Notes: Accessible spaces are not painted blue. ISA faded. Stall is 16'-6" long (18' required). 4 accessible spaces are provided (5 required for 138 spaces).		
State: 1129B.1, 1129B.3, 1129B.4		
Federal: -		
Provide or modify accessible access aisles		\$1,000
Notes: Access aisle is not outlined in blue. The words "No Parking" are not painted at the access aisle. Access aisle is 16'-6" long (18' required). Tree root crack.		
State: 1129B.3, 1129B.3.1		
Federal: -		
Install sign		\$500
Notes: No "Minimum Fine \$250" sign posted.		
State: 1129B.4		
Federal: -		
Install sign for unauthorized parking		\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.		
State: 1129B.4		
Federal: -		

Parking Lot 9 PROW

1 - 3		Parking Area	Priority: 1
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded. Stall is 8'-3"x17'-9" long (9'x18' required). 4 accessible spaces are provided (5 required for 138 spaces).			
State: 1129B.1, 1129B.3, 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: Access aisle is not outlined in blue. The words "No Parking" are not painted at the access aisle. Access aisle is 15'-9" long (18' required).			
State: 1129B.3, 1129B.3.1			
Federal: -			
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Slopes of access aisle are 2.1%-3.6% (2% max.)			
State: 1129B.3.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			

Parking Lot 9 PROW

1 - 4		Parking Area	Priority: 1
Provide or modify accessible spaces			\$500
Notes: Accessible spaces are not painted blue. ISA faded. 4 accessible spaces are provided (5 required for 138 spaces).			
State: 1129B.1, 1129B.4			
Federal: -			
Provide or modify accessible access aisles			\$1,000
Notes: Access aisle is not outlined in blue. The words "No Parking" are not painted at the access aisle. Access aisle is 17'-8" long (18' required).			
State: 1129B.3, 1129B.3.1			
Federal: -			
Install sign			\$500
Notes: No "Minimum Fine \$250" sign posted.			
State: 1129B.4			
Federal: -			
Regrade surface			\$1,000
Notes: Cross slopes of access aisle are 2.1%-2.4% (2% max.)			
State: 1129B.3.4			
Federal: -			
Install sign for unauthorized parking			\$0
Notes: No posted warning at street entry regarding unauthorized use of accessible spaces and towing information.			
State: 1129B.4			
Federal: -			
3 - 1		Curb Ramp	Priority: 1
Provide detectable warning strip			\$1,000
Notes: Detectable warning pad is 24" deep (36" required).			
State: 1127B.5.7, IR11B-4			
Federal: -			
Provide level landing			\$5,000
Notes: Level landing at top of ramp is sloped at 5.3% (2% max.).			
State: 1127B.5.4			
Federal: -			



1-1

Downtown Parking Lot 10 - PROW
Main Street at State Street
Los Altos, CA

Parking Lot 10 PROW

1 - 1 Parking Area		Priority: 1
Install sign		\$500
Notes:	No "Minimum Fine \$250" sign posted.	
State:	1129B.4	
Federal:	-	
Provide or modify accessible spaces		\$500
Notes:	2 spaces provided. Accessible spaces are not painted blue. ISA faded and not visible when vehicle is present. Stall is 8'-7" wide (9' required).	
State:	1129B.3, 1129B.4	
Federal:	-	
Provide or modify accessible access aisles		\$1,000
Notes:	The words "No Parking" are not painted at the access aisle.	
State:	1129B.3, 1129B.3.1	
Federal:	-	
Install sign for unauthorized parking		\$500
Notes:	No posted warning at street entry regarding unauthorized use of accessible spaces and towing information	
State:	1129B.4	
Federal:	-	