

SECTION 19 ADA PARKING STALLS AND REQUIREMENTS

19-01 GENERAL

Parking stalls for the use of the physically handicapped shall comply with the requirements set forth in Part 2 of Title 24 of the California Administrative Code and Chapter 9 of Division 11 of the Vehicle Code of the state.

The number of handicapped parking stalls shall be provided according to the following, unless drawings or City requirements indicate otherwise:

<u>Total Parking in Lot</u>	<u>Required Accessible Spaces</u>
1 to 25	1
26 to 50	2
51 to 75	3
76 to 100	4
101 to 150	5
151 to 200	6
201 to 300	7
301 to 400	8
401 to 500	9
501 to 1000	2 percent of total
1001 and over	20 plus 1 for each 100 over 1000

Accessible stalls shall be a minimum of nine feet (9') in width and eighteen feet (18') in length. Single stalls shall have an access aisle of eighteen feet (18') long by five feet (5') wide (minimum). Stalls shall conform to the Standard Plans.

One in every eight stalls, and no less than one, shall be designated as Van-Accessible. These stalls shall be served by an access aisle of eighteen feet (18') long by eight feet (8') wide placed opposite the driver's side.

Surface slopes within the accessible parking stalls and access aisles shall be minimized with a maximum allowable slope of two percent (2%), in any direction.

Signage for accessible parking spaces shall conform to Part 2 of Title 24 of the California Administrative Code.